

ORDER TYPE POMTR PO-METER PERMIT

PAGE 1 OF 2

ACCOUNT 1001038472001

NAME CHUNG LUI LAM

PHONE 000-000-0000

ADD NM

BORO 4 BLK 7653 LOT 34

SEC 4 COMM BRD 411

ADDR 230 15 64 AV

SPCL PREM INS

FLUSHING NY 11364

SPCL READ INSTR

BUILDING CLASS

CROSS STREETS

230 STREET

231 STREET

UMS VARIANCE CODE

NON UMS VARIANCE CODE

ASGN TO 0000 STATUS A PEND/INITIATED REAS A NORMAL

ISS DATE 03/10/11

CONTRACT 0000 BATCH 000000 PLACED BY ELBA

PH #

WANTED BY DATE 03/09/12

TIME 0000

CREATED BY MO

DATE 03/09/11

CONTRACT ITEM CODES

SPCL INST PO-METER PERMIT SET NEW 1.5" DISP MTR, BL 7653/34, DOMESTIC, EP RES,  
NEW BLDG

POMTR - PO-METER PERMIT

PERMIT NUMBER 594457

SVC SIZE 004 SVC SIZE DESC 1 - 1/2" TAP SIZE 004 TAP SIZE DESC 1"

FEE 35.00 NO DAYS USAGE 000 START/END DATE 00/00/00 00/00/00

APPLICATION DATE 00/00/00 EXPIRE DATE 00/00/00 START/END TIME 0000 0000

PLUMBER LICENSE NO 0001057 EXPIRE DATE 05/13/12 STATUS A ACTIVE-GOOD

NAME DOMINICK MONACO

ADDRESS 36-09 MAIN STREET SUITE #3E FLUSHING NY 11355

#### ADDITIONAL ORDER INFORMATION

METER PERMIT

NOTE: ALL METERS MUST BE REMOTE READY.

PERMIT ORDER STATUS

☒ G -- PERMIT COMPLETED

☐ P -- PERMIT CANCELED

NEW METER ATTRIBUTE AND NEW METER INSTALLATION INFORMATION FOR

METER NUMBER:

( *Neptune* ) NEW METER MANUFACTURER

( *1 1/2"* ) NEW METER SIZE

( *Displacement* ) NEW METER TYPE

( ) NEW METER LOCATION CODE

( ) NEW METER SERIAL NUMBER

( ) NEW METER READING 1

( ) NEW METER READING 2 (FOR COMPOUND METER)

( ) NEW REMOTE ID 1

( ) NEW REMOTE ID 2 (FOR COMPOUND METER)

( ) NEW REMOTE LOCATION CODE

( ) LOW FLOW - IN-READ/ OUT READ

( ) INTERFLOW - IN-READ/OUT READ

( ) HIGH FLOW - IN-READ/OUT READ

( ) CAPACITY (GALLONS, CUBIC FEET)

( ) NUMBER OF READ DIALS-1

( ) TOTAL NUMBER OF DIALS-1

( ) NUMBER OF READ DIALS-2 (FOR COMPOUND METER)

( ) TOTAL NUMBER OF DIALS-2 (FOR COMPOUND METER)

( ) CONSTANT

( ) MEASURES (CCF, GALLONS)

( ) CAPABILITIES (PB-PRIMARY BYPASS OR MNL-MAINLINE)

( ) SEAL NUMBER 1

( ) SEAL NUMBER 2 (FOR COMPOUND METER)

METER TEST DATE

| | -- | | -- |

All registers shall be installed with wire  
connected to a remote or AMR  
transmitter with all three wires properly  
connected at the register head.



ORDER TYPE POMTR PO-METER PERMIT  
ACCOUNT 1001038472001 NAME CHUNG LUI LAM

PAGE 2 OF 2  
PHONE 000-000-0000

METER TESTED BY (INSPECTOR ID): -

I HERBY CERTIFY THAT ALL CONNECTIONS ARE PROPER AND THAT THE  
PREMISES ARE METERED IN ACCORDANCE WITH THIS PERMIT.

DATE SET: 08/18/2011  
PLUMBER NAME: Dominick J Monaco  
PLUMBER ADDRESS: 3609 main St. #120  
Flushing, NY 11354

IF CALIBRATION WAS REQUIRED, WAS THE METER CALIBRATED IN PLACE?

( ) YES  
( ) NO

|                    |       |                     |       |
|--------------------|-------|---------------------|-------|
| COMPLETION DATE    | _____ | WO STATUS           | _____ |
| COMPLETED BY (ID)  | _____ | WO STATUS REASON    | _____ |
| COMPLETION TIME IN | _____ | COMPLETION TIME OUT | _____ |

COMMENTS



83043430

| TEST % | FULL | INTER | LOW  |
|--------|------|-------|------|
|        | 99.  | 100.2 | 98.2 |

Intermediate Bench  
1 1/2 T10  
DM2H11  
Pos # 7  
Gear Reg.

SB

03/10/11 14:03 PM



000010020002

Equipe  
Serial