



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11375
ASBESTOS ASSESSMENT REPORT



1. NYC Buildings Dept. Application # _____
2. Premise No. 142-30 Street Name 58th Road Borough Queens Zip 11355
3. AKA _____ Type of Facility Residence BIN 4140238 Block 06408 Lot 0041
4. Building Owner Guo Hui Zheng Address 142-30 58th Road
5. City Flushing State NY Zip 11355 Contact Person Sam Lin
6. Tel. # (718) 321-7818 Fax # _____ Email _____
7. Description of the Entire Scope of Work
Demolish existing 1 family, 1 1/2 story frame/brick residence.

8. I, PAUL ATHINEOS, have conducted an asbestos investigation on 12/22/2010 in accordance
Name of Certified Asbestos Investigator Date
with Sections 1-16 and 1-28 of the NYC DEP Asbestos Control Program Rules and declare that at said facility address, the
☐ a. premise (or portions thereof) affected by the work is free of asbestos containing material (ACM).
☒ b. premise (or portions thereof) affected by the work contains 10 square feet or less or 25 linear feet or less of ACM.
Specify locations in section 9:
Note: This material must be abated as a minor project in accordance with relevant provisions of the DEP Asbestos Rules.
☐ c. asbestos is present and will not be disturbed during construction activity. Specify the quantity and area where asbestos
is present.
Specify amount: _____ sq. ft. _____ linear ft.
Specify locations (attach additional documents as necessary): _____

9. RESULTS OF ASBESTOS BUILDING SURVEY:

FLOOR	DESCRIPTION SECTION OF FLOOR	ALL MATERIALS ASSUMED TO CONTAIN ACM AND/OR SAMPLED	NUMBER OF SAMPLES ANALYZED	ASBESTOS PRESENT	ASSUMED ACM
Cellar	Entire Cellar	The following items were inspected: Chimney/flue seal at boiler is assumed ACM. Ceiling tiles were sampled. Floor is concrete with carpeting. All pipes exposed were copper, cast iron and sheet-metal with no insulation/pipe wrap.	2	No	Yes

I hereby declare the information provided herein is true and complete

Paul W. Athineos
DEP Certified Asbestos Investigator's Signature

2/1/2011
Date

113453
Certificate Number

2/28/2011
Expiration Date

Tel. # (631) 686-6472 Fax # _____ Email paul@architectsrule.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.

SEAL
OF THE
NYC DEP
CERTIFIED
ASBESTOS
INVESTIGATOR



2227458

**NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION**Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373**ASBESTOS ASSESSMENT REPORT**

First Floor	Entire First Floor	The following items were inspected: Plaster walls were sampled. Wood floors and base molding throughout. Ceramic tile in bathroom. Exterior siding is brick with aluminum trim.	7	No	No
Attic	Entire Attic	The following items were inspected: Gypsum wall board and ceiling tile were sampled. Fiber-glass insulation between roof rafters.	3	No	No
Roof	Entire Roof	The following items were inspected: Chimney/flue seal at roof is assumed ACM. Asphalt roof shingles (core) were sampled. Should any suspect friable ACM be encountered during construction, contractor shall stop work immediately and notify investigator.	3	No	Yes

10. Analytical Laboratory NY Environmental & Analytical Laboratories, Inc11. ELAP # 11510 Date(s) Samples Analyzed 12/23/2010
NYS DOH CERTIFICATION

I hereby declare the information provided herein is true and complete

DEP Certified Asbestos Investigator's Signature

2/1/2011

Date

113453

Certificate Number

2/28/2011

Expiration Date

Tel. # (631) 686-6472

Fax # _____

Email paul@architectsrule.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.

SEAL
OF THE
NYC DEP
CERTIFIED
ASBESTOS
INVESTIGATOR



2227458