



Department of Buildings
Executive Office:
280 Broadway
New York, New York 10007



TCU Audit of Professionally Certified D-14 Jobs Plan Examiner Checklist and Notice of Objections

Applicant: Umer Shah	Date: May 27, 2011
	Job Application: 420358062
	Application Type: Alt 2
	Premises Address: 107-35 133 Street
	District: R3-2
Block:	Lots:
NYC Department of Buildings Examiner: Tat C. Wong, P.E.	
Audit Status: 10 DAY	<i>*If not responded within ten days, permit will be revoked.</i>

No.	Code	Objection	Resolved on
1		<i>Please bring application folder, perforated plans and amendments for the next appointment. If folder is not found, bring a 'Not Found' slip from the Records Room, otherwise appointment will be noted as 'Not Prepared'.</i>	
2		For three piece bath in the cellar: Restrictive declaration shall be filed and recorded prohibiting use of the cellar level for living, sleeping, cooking or separate rental.	
3		Questionable cellar layout. Remove existing kitchen sink and kitchen counter.	
4		Clarify existing metal shed indicated on drawing. Provide approved plans for Job 401517541.	
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			