



May 4, 2012

Robert Fallacara
EmPower Solar
221 Long Beach Rd
Island Park, NY 11558

Re: 147-03 14 Ave
Whitestone, NY 11357
WR #1261505
Solar Power Installation



Dear Mr. Fallacara,

Please be advised that the interconnection application, including the **Contractor Certification and the three-line diagram accepted by Consolidated Edison**, for the Photovoltaic Distributed Generation Installation at the above - referenced address has been reviewed and is accepted for inter-connection to and operation in parallel with the Consolidated Edison system as of 05/04/12.

You are advised that this authorization is limited to a determination that the installation described above is accepted by Consolidated Edison and does not mean that the design and installation of your DG equipment is in compliance with any other requirements, including local building codes and ordinances. **You are reminded that your contract for the Interconnection of a New Distributed Generation Unit with a Capacity of 2 MW or Less requires the Customer to obtain all environmental and other permits required by governmental authorities for the construction and operation of the Unit.**

Finally, you are reminded of the requirement to contact Consolidated Edison to obtain approval before any modifications is made to your equipment. You are further reminded of the continuing obligation to perform verification testing at least once every four years as well as any verification tests prescribed by the manufacturer and to maintain a log of these tests for inspection by Consolidated Edison.

Sincerely,

Alonzetta Abraham

Alonzetta Abraham
B/Q Major Services

cc: Michael Capello
147-03 14 Ave
Whitestone, NY 11357