



AI1: Additional Information

Must be typewritten.



Page number 1 of 1

BIS Document No. 021

1 Location and Job Information Required for all applications.

House No(s) 204-07 Street Name MARSHALL AVENUE ROCKAWAY POINT
Borough QUEENS Block 16350 Lot 300 BIN 4464712 CB No. 414

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes PW1 required ☐ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID
S	EN-100.	EN-100.	S	Z-100.	Z-100.						
	00	01		01	02						
S	A-100.	A-100.									
	01	02									

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page.

Is this section continued on additional AI1 forms? ☐ Yes ☐ No

3 Additional Information Required for all applications.


The following is submitted in response to Energy Code Objections by the plan examiner.

- 1 & 2 & 3. PW-1 forms corrected
4. TR-8 form corrected
5. Citation corrected on plans
6. Thermal values in ResCheck analysis and on plans coordinated and updated
- 7.-8. ResCheck updated to include completion of checklist.
9. Energy Code progress inspection in tabular format added to EN-100 drawing.
10. EN-100 drawing added to set of plans with all required information.
11. Thermal Boundary drawing provided on EN-100 drawing.
12. Tight fitting non-combustible doors added at fireplace on A-100 drawing.
13. Location of Permanent Certificate noted on A-100 drawing.
14. Mandatory air leakage requirements indicated in Notes on EN-100 drawing.
- 15- Not Applicable
16. - 19. These objections are covered by notes contained on EN-100 drawing.
20. Equipment size noted on EN-100 drawing.

NYC Department of Buildings
Energy Code Compliance
Accepted Following Audit

Examiner: Natacha Dartois
Date: Assistant Sustainability Plan Examiner

**AMENDED
APPLICATION**



Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print) Gary D. Lennhart, RA
Signature [Signature] Date 7/9/14
P.E. / R.A. Seal (apply seal, then sign and date over seal)