




NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11355
ASBESTOS ASSESSMENT REPORT



1. NYC DOB Job # (if applicable) _____ **Control Number: 4418078**
2. Premise No. 94-23 Street Name 42ND AVE Borough Queens Zip 11373
3. AKA _____ Type of Facility Residence BIN 4039710 Block 01591 Lot 0081
4. Building Owner MIN CHEN Address 94-23 42ND AVE
5. City Queens State NY Zip 11373 Contact Person Angel Feng
6. Tel # (917) 378-3318 Fax # _____ Email ms.angel.feng@gmail.com
7. Description of the Entire Scope of Work
PROPOSE CONVERSION FROM ONE TO TWO DWELLING UNIT WITH PARTITION AND PLUMBING WORK AS PER PLAN FILED
HEREWITH. REQUEST A NEW CERTIFICATE OF OCCUPANCY.

8. I, DE GAO, have conducted an asbestos investigation on
Name of Certified Asbestos Investigator
05/09/2018 2:15PM-3:15PM in accordance
Date(s)
with Sections 1-16 and 1-28 of the NYC DEP Asbestos Control Program Rules and declare that at said facility address, the
☒ a. portion(s) of the premises affected by the work is free of asbestos containing material (ACM).
☐ b. premise (or portions thereof) affected by the work contains 10 square feet or less or 25 linear feet or less of ACM.
Specify locations in section 9: Note. This material must be abated as a minor project in accordance with relevant provisions of the DEP Asbestos Rules.
☐ c. asbestos is present and will not be disturbed during construction activity. Specify the quantity and area where asbestos
is present. Specify amount: _____ sq. ft _____ linear ft.
Specify locations (attach additional documents as necessary): _____

☐ d. entire building is free of asbestos containing material (ACM).


9. RESULTS OF ASBESTOS BUILDING SURVEY.

LOCATION	FLOOR NUMBER	DESCRIBE SECTION OF FLOOR	ALL MATERIALS ASSUMED TO CONTAIN ACM AND/OR SAMPLED	NUMBER OF SAMPLES ANALYZED	ASBESTOS PRESENT	ASSUMED ACM
Facade	1	side facade	siding	2	No	No
Facade	1	side facade	insulation behind siding	2	No	No
Cellar		open cellar	ceiling tile	1	No	No
Building Floors	1	front room	ceiling tile	1	No	No
Cellar		bathroom	caulking	1	No	No

I hereby declare the information provided herein is true and complete

DE GAO 5/14/2018 148844 6/10/2020
DEP Certified Asbestos Investigator's Signature Date Certificate Number Expiration Date
Tel. # (917) 683-2790 Fax # _____
Email dgsafetyny@gmail.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86, 40 CFR 763.80, 40 CFR 763.85



Is it a Build-It-Back project? ☐ Yes, App ID # _____ ☒ No





NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373
ASBESTOS ASSESSMENT REPORT



Building Floors	2	bathroom	caulking	1	No	No
Building Floors	1	front room	vinyl tile	2	No	No
Building Floors	1 to 2	partition	plaster	5	No	No
Attic		stair	plaster	1	No	No

10. ANALYTICAL LABORATORY:

NAME	ELAP # (NYS DOH CERTIFICATION)	DATE(S) SAMPLES ANALYZED
ATC Group Services LLC	10879	5/10/2018
ATC Group Services LLC	10879	5/14/2018


11. NYS DOL Asbestos Handling license # 105312 Company Name DG Safety NY LLC

I hereby declare the information provided herein is true and complete

DE GAO [Signature] 5/14/2018 148844 6/10/2020
DEP Certified Asbestos Investigator's Signature Date Certificate Number Expiration Date
Tel # (917) 683-2790 Fax # _____

Email dgsafetyny@gmail.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86, 40 CFR 763.80, 40 CFR 763.85.



Is it a Build-It-Back project? ☐ Yes, App ID # _____ ☒ No



25438067