



4/5/2018

Vincent Sapienza, P.E.
Commissioner

Ameriland Brook, LLC
33-70 Prince Street, Suite # 906
Flushing, New York 11354
Attn: Xiaohong Zhao, P.E.

DEPT BLDGS Job No. 421569216
Scan Code ESHS6605292

To Whom It May Concern:

Anastasios Georgelis, P.E.
Acting Deputy
Commissioner
Bureau of Water &
Sewer Operations

59-17 Junction Boulevard
Flushing, NY 11373

The hydrant flow test you requested in the vicinity of **138-15 58th Avenue, Queens** was performed on **4/4/2018** at **8:53 AM** with the following results:

The static pressure taken on an 8 inch water main which is fed from two directions on the north side of 58th Avenue 1st hydrant east of 138th Street was **46** pounds per square inch. The residual pressure at this point was **44** pounds per square inch when 500 gallons of water per minute were flowing from the north side of 58th Avenue 1st hydrant west of 138th Street.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

If you have any questions regarding engineering, and application status, please call (718) 595-7135.

Very truly yours,

Urszula Krajewski, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2017-3146-427232

All hydrant flow test requests are to be addressed to: NYCDWP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$500 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.