



TR4: Technical Report
Soil Investigation
Must be typewritten.

☒ Orient and affix BIS
job number label here ☒

1 Location Information Required for all applications.

House No(s) 56-25 Street Name ROOSEVELT AVENUE
Borough QUEENS Block 1240 Lot 74 BIN 4028450 CB No. 402
Work on Floor(s) Apt/Condo No(s)

2 Applicant Information Required for all applications.


Last Name PARBHUNATH First Name INDARDEO Middle Initial
Business Name IP CONCRETE TESTING & INPECTION INC Business Telephone 718-641-5800
Business Address 101-01 101 AVENUE Business Fax
City QUEENS State NY Zip 11416 Mobile Telephone
E-Mail aainspectionsbuildings@gmail.com License Number 083868
☒ P.E. ☐ R.A.

3 Required Borings / Test Pits Required for all applications.

Number of Test Pits as Required as per NYC Construction Codes: B-1

4 Plot Diagram Required for all applications.

Draw in ink to indicate scale. Show building outline or extension and location of all borings and/or test pits by dimensions. Borings and/or test pits shall be distributed according to the NYC Construction Codes.



5 Test Report *Required for all applications.*

Date	Boring/ Test Pit #	Feet Below Curb	Soil Description	Class Number	Remarks
6/16/20	B-1	0-2	sandy clay silt ,gravel	6	Uncontrolled fill
		2-4	black sandy clay (sc	3b	Natural fill
		4-6	brown clayey clay (sc	3b	Natural fill
		6-8	brown sandy clay with gravel (sc	3b	Natural fill
		8-10	brown sandy clay(sc	3b	Natural fill
		10-12	brown sandy clay(sc	3b	Natural fill
		12-14	brown fine sand (sm	3b	Natural fill
		14-16	coarse sand (sm	3a	Natural fill
		16-18	coarse sand (sm	3a	Natural fill
		18-20	coarse sand with moisture (sm	3a	Natural fill
		20-22	coarse sand (sm	3a	Natural fill
		22-24	coarse sand (sw	3a	Natural fill
		24-26	coarse sand with gravel (sw	3a	Natural fill
		26-28	coarse sand with gravel (sw	3a	Natural fill
		28.5ft	Hit rock 28.5ft spoon refusal		

6 Statements and Signatures *Required for all applications.*

I hereby state that the above information is correct and complete to the best of my knowledge and that the above tests were performed in accordance with all Administrative Code Provisions and Departmental Rules, Regulations and Directives.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both.

It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both.


Name (please print)

INDARDEO PARBHUNATH

6/16/2020

Signature

Date



P.E. / R.A. Seal (apply seal, then sign and date over seal)

Approvals - Internal Use Only

Examined and Recommended for Approval		Approved	
Examiner Name		Borough Commissioner Signature	Date
Signature	Date		