



nem srs <nem-srs@sunrunhome.com>

223-31 110TH AVENUE, QUEENS, NY 11429 [MC-192249]

dl-ESWEBPSNQ@coned.com <dl-ESWEBPSNQ@coned.com>

Thu, Jun 2, 2016 at 11:04 AM

To: nem-srs@sunrun.com

Cc: jahlove61@aol.com

June 2, 2016

Re: INTERCONNECTION FINAL APPROVAL

223-31 110th Avenue**Queens, NY 11429****Case: MC-192249**

Dear Sir/Madame:

Your interconnection application at the above referenced location **is approved** to operate in parallel with the Consolidated Edison system **as of 6/2/16**.

This authorization is limited to a determination that the installation described above is accepted by Consolidated Edison Company of New York. You are required to ensure that your DG equipment is in compliance with any other jurisdictions, including local building codes and ordinances. You are reminded that your contract for the "Interconnection of a New Distributed Generation Unit with a Capacity of 2 MW or Less" requires the Customer to obtain all environmental and other permits required by governmental authorities for the construction and operation of the Unit.

If there are any modifications made to your equipment after the date of approval, you must contact Consolidated Edison Company of New York. You are further reminded of the continuing obligation to perform verification testing at least once every four years as well as any verification tests prescribed by the manufacturer. You must maintain a log of these tests for inspection by Consolidated Edison Company of New York.

For billing inquiries, please contact us via email at NetMetering@coned.com, by phone at 212-780-6600, or you can visit our website www.coned.com/Solar for answers to frequently asked questions. In addition, please be advised that if the customer's account is enrolled in Con Edison's 'Level Payment Plan', the customer should contact us.

Sincerely,

Rosanna Zranchev

Sr Specialist

Con Edison Company of NY

dl-ESWEBPSNQ@coned.com

(W) 212-460-6505

conEd.com

2 attachments

 **desktopimages/LogoBottom_Coned.jpg**
4K

 **desktopimages/LogoBottom_Coned.jpg**
4K