

BREEZY POINT COOPERATIVE, INC.



202-30 ROCKAWAY POINT BLVD.
ROCKAWAY POINT
NEW YORK 11697
Tel. 718-945-2300
Fax: 718-634-0261

APP-022111

July 13, 2016

NYC Department of Buildings
120-55 Queens Blvd.
Kew Gardens, NY 11424

RE: 1 Suffolk Walk

Gentlemen:

This is advice that the Breezy Point Cooperative, Inc. Field Department performed a flow test on the hydrants closest to 1 Suffolk Walk. Static pressure at the hydrant at 1 Suffolk Walk and Oceanside was 51psi. Residual pressure with 500 GPM flowing at the hydrant at 28 Tioga Walk and Oceanside was 47psi. This test was performed on an 8" main being fed from two directions.

Sincerely yours,

A handwritten signature in blue ink, appearing to read 'Arthur C. Lighthall', with a long horizontal flourish extending to the right.

Arthur C. Lighthall
General Manager

ACL/mb
cc: Con Jacket