




# AI1: Additional Information Must be typewritten.



Page number 1 of 1 BIS Document No. \_\_\_\_\_

## 1 Location and Job Information Required for all applications.

House No(s) 13 Street Name West 16 Road  
Borough Queens Block 15320 Lot 45 BIN 42 CB No. 414

## 2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes PW1 required ☐ No Indicate all actions for this submission:

| Action | Original/New/<br>Omit Page ID | Superseding<br>Page ID | Action | Original/New/<br>Omit Page ID | Superseding<br>Page ID | Action | Original/New/<br>Omit Page ID | Superseding<br>Page ID | Action | Original/New/<br>Omit Page ID | Superseding<br>Page ID |
|--------|-------------------------------|------------------------|--------|-------------------------------|------------------------|--------|-------------------------------|------------------------|--------|-------------------------------|------------------------|
|        |                               |                        |        |                               |                        |        |                               |                        |        |                               |                        |
|        |                               |                        |        |                               |                        |        |                               |                        |        |                               |                        |
|        |                               |                        |        |                               |                        |        |                               |                        |        |                               |                        |
|        |                               |                        |        |                               |                        |        |                               |                        |        |                               |                        |

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page. Is this section continued on additional AI1 forms? ☐ Yes ☒ No

## 3 Additional Information Required for all applications.

As per GCL-35 Waiver Coversheet( Section3.4), App# 024525 is exempt from sprinkler requirements contingent upon FDNY review. Two story single family wood frame structure is not required to be sprinklered based on Chapter 4-1 & 4-2 1968 building Code.

FDNY reviewed this application and approved on 5-21-20 under HRO submission # 1589221434194 based upon DOB approved Drawings.

The DOB approved drawings were under Document 4 on 3-7-2018.

See attached letter from HRO titled Audit Outcome of GCL Submission- FDNY.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print) TERENCE HAIRSTON 8/11/22  
Signature [Signature] Date  
P.E. / R.A. Seal (apply seal, then sign and date over seal)





**FROM:** NYC Housing Recovery Operation  
**TO:** NYC Department of Building  
**APP ID:** 024525  
**DOB JOB ID:** 440330410  
**ADDRESS:** 13 West 16 Road Queens, NY

---

## Audit Outcome of GCL 35 Submission- FDNY

---

## FDNY Review outcome of GCL 35 Submissions

SUBMISSIONS : REVIEWER FORM ▾

Submission-1589221434194 ≡

### FDNY Reviewer Section

FDNY Review Decision

Approved

FDNY Reviewed By

Ryan Paholek

FDNY Reviewer Comments

as per information included in application and submission information this application has filed to be exempt from sprinklers, requires 2hr underbelly

FDNY Reviewed Date

5/21/2020