

BREEZY POINT COOPERATIVE, INC.



202-30 ROCKAWAY POINT BLVD.
ROCKAWAY POINT
NEW YORK 11697
Tel. 718-945-2300
Fax: 718-634-0261

March 30, 2016

NYC Department of Buildings
120-55 Queens Blvd.
Kew Gardens, NY 11424

RE: 120 Reid Ave.
Rockaway Point, NY 11697

Gentlemen:

This is advice that the Breezy Point Cooperative, Inc. Field Department performed a flow test on the hydrants closest to 120 Reid Avenue. Static pressure at the hydrant at the rear of 135 Reid Avenue was 50 P.S.I. Residual pressure with 500 G.P.M. flowing at the hydrant at the rear of 111 Reid Avenue was 48 P.S.I. This test was performed on an 8" main being fed from two directions.

Sincerely yours,

A handwritten signature in blue ink, appearing to read 'Arthur C. Lighthall'. The signature is fluid and stylized, with a long horizontal stroke at the end.

Arthur C. Lighthall
General Manager

ACL:lb

cc: Lease
Con jacket