



Carter H. Strickland, Jr.
Commissioner

James J. Roberts, P.E.
Deputy Commissioner
Bureau of Water &
Sewer Operations
jroberts@dep.nyc.gov

59-17 Junction Boulevard
Flushing, NY 11373

10/4/2013

Manouvelos Engineering, P.C.
30-53 Crescent Street
Long Island City, New York 11102
Attn: Peter Manouvelos

To Whom It May Concern:

The hydrant flow test you requested in the vicinity of **57-45 Rust Street, Queens** was performed on **10/3/2013** at **10:58 AM** the following results:

The static pressure taken on the north side of 57th Road 1st hydrant east of Rust Street was 72 pounds per square inch. The residual pressure at this point was 68 pounds per square inch when 500 gallons of water per minute were flowing from the east side of 58th Street 1st hydrant south of 57th Road.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

The flow test was performed on an 8 inch water main, which is fed from one direction.

If you have any questions regarding engineering, please contact (718) 595-7440, and for application status, please call (718) 595-3512.

Very truly yours,

A handwritten signature in black ink that reads "Dudley Pierre".

Dudley Pierre, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2013-1699-436-258

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$500 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.