



AI1: Additional Information

Must be typewritten.

DEPT BLDGS Job No. 440411582



Scan Code ESHS5788495

Page number 1 of 1

BIS Document No 03

1 Location and Job Information Required for all applications.

House No(s) 6-09

Street Name 161 STREET

Borough QUEENS

Block 04574

Lot 00018

BIN 4103985

CB No. 407

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☒ Yes PW1 required ☐ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID
S	T-001.01	T-001.02									
S	A-100.01	A-100.02									
S	A-101.00	A-101.01									
S	A-102.00	A-102.01									

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page.

Is this section continued on additional AI1 forms? ☐ Yes ☒ No

3 Additional Information Required for all applications.

DOB SUMMONS#35307491H:

- (DOB) "Attic (2) windows not show on plan, cel. rear & attic stairs no h/rails"
(BEDPC response) Existing (2) attic windows amended on dwg. A-101 and clouded. Cellar rear and attic stairs added to dwgs. A-100 and A-101 and clouded.
- (DOB) "1st floor exterior front and side stairs not shown on plan, side canopy found (2) poles, plan show (4). Also side porch & second door to bathroom not shown on plan."
(BEDPC response) 1st floor exterior front stairs and side porch are existing to remain; dwg. T-001 plot plan amended and clouded. New side stairs added to dwg. A-100 and clouded. Side canopy detail amended to show (2) poles on dwg. A-100 and clouded. Second door to 1st floor bathroom added to dwg. A-100 and clouded.
- (DOB) "Cel. boiler (rm), 1st fl. living (rm) with fireplace no s/cm detectors"
(BEDPC response) Smoke/Carbon Monoxide detectors relocated to cellar boiler room on dwg. A-100 and clouded. Smoke/Carbon Monoxide detectors added to 1st floor living room on dwg. A-100 and clouded.
- (DOB) "Cel. partitions (boiler rm, laundry rm, storage rm & stair wall) not as per plan."
(BEDPC response) Cellar partitions amended to reflect as built condition on dwg. A-100 and clouded.
- (DOB) "AC units relocated to side not as per plan"
(BEDPC response) AC units location amended per as built condition on dwgs. A-100 and A-101 and clouded.
- (DOB SEP 04/24/18 comment) "Provide elevation of lowest floor"
(BEDPC response) Dwg. A-102 amended to add elevation certificate.

Shameem Begum

JUN 19 2018

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any gratuity or other consideration, either as a gratuity for properly performing the job or in consideration for any action taken or to be taken. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print)

SING MAN KEVIN CHENG

Signature

Date

P E / R.A. Seal (apply seal and date over seal)

