

dl-ESWEBPSNQ@coned.com
to jacchang, me

8:39 AM (23 hours ago)

Reply



Consolidated Edison Company Of New
York, Inc
Queens Energy Services
[30 Flatbush Avenue, 6th Floor](#)
Brooklyn, NY 11217-1121

Date: October 31, 2017
Service At: [245-24 149 Ave](#) 2fl
Rosedale, NY 11422
Case Number: MC-295981

Dear Jacqueline Chang,

Your interconnection application for the above location has been **approved** to operate in conjunction with Con Edison's system.

This authorization is limited to a determination that the installation described above has been accepted by Con Edison. It is your responsibility to ensure that your DG equipment is in compliance with any other jurisdictional codes and ordinances, and as per your contract you are required to obtain all environmental and other permits necessitated by governmental authorities for the construction and operation of the unit.

If there are any modifications made to your equipment after the date of approval, you must contact us. Upon activation of your system, you assume the continuing obligation to perform verification testing once every four years (at minimum), as well as any verification tests prescribed by the manufacturer. You must maintain a log of these tests for inspection by Con Edison.

Please contact us at NetMetering@conEd.com or at [212-780-6600](tel:212-780-6600) with any billing inquiries*, or you can visit our [website](#) for answers to frequently asked questions.

****If you are currently enrolled in Con Edison's Level Payment Plan please contact us to be removed. This plan is not beneficial for solar customers***

Sincerely,

Rosanna Zranchev

Sr Specialist

Con Edison Company of NY

Queens Energy Services

[30 Flatbush Avenue, 6th Floor](#)

[Brooklyn, NY 11217-1121](#)

dl-ESWEBPSNQ@coned.com

(W) [212-460-6505](tel:212-460-6505)