

Final Acceptance Letter 94-47 133 AVENUE, QUEENS, NY 11417 [MC-299065]

DEPT BLDGS Job No. 440432248



Scan Code ESHS2822881

dI-FSWEBPSNQ@coned.com

Wed: 11/29/2017 2:27 PM

To: Utility <Utility@MomentumSolar.com>;

cc: Utility <Utility@MomentumSolar.com>; Utility <Utility@MomentumSolar.com>;

1 attachment (29 KB)

desktopimagesConEd_B1Logo.png;



Consolidated Edison Company Of
New York, Inc
Queens Energy Services
30 Flatbush Avenue, 6th Floor
Brooklyn, NY 11217-1121

Date: November 29,
2017
Service At: 94-47 133
Avenue
Queens, NY
11417
**Case
Number:** MC-299065

Dear Nicholas Rimpici,

Your interconnection application for the above location has been approved to operate in conjunction with Con Edison's system.

This authorization is limited to a determination that the installation described above has been accepted by Con Edison. It is your responsibility to ensure that your DG equipment is in compliance with any other jurisdictional codes and ordinances, and as per your contract you are required to obtain all environmental and other permits necessitated by governmental authorities for the construction and operation of the unit.

If there are any modifications made to your equipment after the date of approval, you must contact us. Upon activation of your system, you assume the continuing obligation to perform verification testing once every four years (at minimum), as well as any verification tests prescribed by the manufacturer. You must maintain a log of these tests for inspection by Con Edison.

Please contact us at NetMetering@conEd.com or at 212-780-6600 with any billing inquiries or you can visit our website for answers to frequently asked questions.*

**If you are currently enrolled in Con Edison's Level Payment Plan please contact us to be removed. This plan is not beneficial for solar customers*

Sincerely,

Rosanna Zranchev

Sr Specialist

Con Edison Company of NY

Queens Energy Services

30 Flatbush Avenue, 6th Floor

Brooklyn, NY 11217-1121

dl-ESWEBPSNQ@coned.com

(W) 212-460-6505