




AI1: Additional Information Must be typewritten.



Page number 1 of 1 BIS Document No. 02

1 Location and Job Information Required for all applications.

House No(s) 138-20 Street Name 223RD STREET
Borough QUEENS Block 13136 Lot 00147 BIN 4282176 CB No.

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes PW1 required ☒ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID
S	A-100.01	A-100.00									
S	A-101.01	A-101.00									

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page. Is this section continued on additional AI1 forms? ☐ Yes ☐ No

3 Additional Information Required for all applications.

Herewith file plan updated to address 06.27.2018 Quality Assurance Audit Comments:

Objection 1: Support of Excavation is required when the excavation is below 5 feet

Resolution of Objection 1: The plan is amended to show new shoring details at Sheet A-101.01 Detail 3 – Shoring Details/Notes.

Objection 2: The violation states that egress is being created, to show the egress out of the cellar floor

Resolution of Objection 2: The plan is amended to show interior stair from Cellar to 1st Floor as the primary egress out of Cellar as depicted on Sheet A-100.01 Detail 1A – Part Cellar Plan. Note, the new proposed exterior stair is a convenience stair only and not a required egress stair.

Objection 3: Comply with BC 2014 1009.4.2 for riser height and tread depth

Resolution of Objection 3: The plan is amended to show riser/tread detail at Sheet A-100.01 Detail 2 Stair Section A-A, Detail 3 Stair Section B-B and Sheet A-101.01 Detail 3 Section B-B (Structural) in compliance with BC 2014 1009.4.2 (Note - Riser: 7" Max; 4" Min, and Tread: 11" min).

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print)

DAVID OXLEY

Signature

Date

P.E. / R.A. Seal (apply seal, then sign and date over seal)

