



Rochelle Smith <rochelle.smith@venturesolar.com>

Final Acceptance Letter 75-07 172nd Street, Queens, NY 11366 [MC-399164]

1 message

dl-ESWEBPSNQ@coned.com <dl-ESWEBPSNQ@coned.com>
To: avnerz1@yahoo.com
Cc: alex@venturehomesolar.com, rochelle.smith@venturesolar.com

Fri, Apr 19, 2019 at 2:59 PM



Consolidated Edison Company Of New York, Inc
Queens Energy Services
[30 Flatbush Avenue, 6th Floor](#)
Brooklyn, NY 11217-1121

Date: April 19, 2019
Service At: [75-07 172nd Street](#)
[Queens, NY 11366](#)
Case Number: MC-399164

Dear Lena Sianov,

Your interconnection application for the above location has been approved to operate in conjunction with Con Edison's system.

This authorization is limited to a determination that the installation described above has been accepted by Con Edison. It is your responsibility to ensure that your DG equipment is in compliance with any other jurisdictional codes and ordinances, and as per your contract you are required to obtain all environmental and other permits necessitated by governmental authorities for the construction and operation of the unit.

If there are any modifications made to your equipment after the date of approval, you must contact us. Upon activation of your system, you assume the continuing obligation to perform verification testing once every four years (at minimum), as well as any verification tests prescribed by the manufacturer. You must maintain a log of these tests for inspection by Con Edison.

Please contact us at NetMetering@conEd.com or at 212-780-6600 with any billing inquiries*, or you can visit our [website](#) for answers to frequently asked questions.

***If you are currently enrolled in Con Edison's Level Payment Plan please contact us to be removed. This plan is not beneficial for solar customers**

Sincerely,
Rosanna Zranchev
Sr Specialist
Con Edison Company of NY
Queens Energy Services
[30 Flatbush Avenue, 6th Floor](#)
[Brooklyn, NY 11217-1121](#)
dl-ESWEBPSNQ@coned.com
(W) 212-460-6505

