



AI1: Additional Information

Must be typewritten.

☒ Orient and affix BIS job number label here ☒

Page number 1 of 1 BIS Document No. 01

1 Location and Job Information *Required for all applications.*

House No(s) 31-07 Street Name 14th St

Borough Queens Block 533 Lot 24 BIN 4441800 CB No. 401

2 Revisions to Plans/Drawings *Required whenever updating plans. All revisions for each page must be clearly described in section 3.*

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes *PW1 required* ☒ No *Indicate all actions for this submission:*

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page.

Is this section continued on additional AI1 forms? ☐ Yes ☒ No

3 Additional Information *Required for all applications.*

Respectfully requesting to file a post approval amendment for minor changes to plan-set and forms

Amend PW2 form to show change in location information.

Amend TR1 and TR8 forms to show change in location information as well as applicant information and to seal.

Amend plan to show proposed location of electrical circuit box/ inverters located in basement, path to equipment on exterior and the location of elevation.

Amend plan to show All elevations noted referred to and clearly identified as the North American vertical datum of 1988.

Amend plan to show that the elevations provided accurately represent existing conditions. The entire lot elevations. One along 14th Street and one along 31st Avenue showing the solar panel installation and FDNY access between different heights roof by way of ladders.

Amend plan to show the compliance with Zoning Resolution height, the indication of the setback requirements the zoning height and setback envelope demonstrating that the solar electric and generating system complies with height and setback regulations as prescribed by the New York City Zoning Resolution.

Amend plan to show the clear location of vent stacks and that the solar canopy does not cover the vents stacks.

Amend plan to show roof plan that demonstrates the solar electric generating system does not obstruct access for both firefighting and maintenance of all roof equipment.

Amend plan to show that this is a stair bulkhead.

Amend plan to show that this is a lower roof and the compliance with FDNY clear path at lower roofs and ladders for connecting upper with lower roofs for FDNY personnel use.

Amend plan to show that roof accurately represent existing conditions the missing vent stacks, chimneys, hatches, skylights, etc. as applicable and also clear dimensions showing compliance with all required clearances, paths, etc. also show legend for all graphics shown on roof plan.

Amend plan to show the construction exceeding the greater of \$40,000 or 25% of market value of structure, the applicant shall provide a substantial improvement calculation and documentation per 1-RCNY 3606-01 to ensure that the building is not being substantially improved. Applicant shall include the statement, "Work proposed in this application (is/is not) included in a substantial improvement as defined by Section BC G201.2 and 1-RCNY 3606-01."

Amend plan to show Flood Insurance Rate Maps - FIRM 2007 & PFIRM 2013/2015

Amend plan to show 1 RCNY Minimum requirements:

- North arrow
- Streets – distance to street
- Dimension of lot
- Block/Lot
- Adjacent buildings (if attached/semi-detached)
- Building height/stories
- Panel locations
- Trees, utility poles – or other falling hazards.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print)

NAVEEN KUMAR 100593

Signature

Date

31/10/2019

P.E. / R.A. Seal (apply seal, then sign and date over seal)