



AI1: Additional Information Must be typewritten.

☒ Orient and affix BIS job number label here ☒

Page number 1 of 1 BIS Document No. _____

1 Location and Job Information Required for all applications.

House No(s) 58-74 Street Name 57TH STREET

Borough QUEENS Block 2631 Lot 106 BIN 4959130 CB No. 405

2 Additional Information Required for all applications.

THE FILED APPLICATION IS COMPLETED AS REQUIRED AS PER TPPN 1/01. I WILL CERTIFY THE REMOVAL OF ALL OBJECTIONS ISSUED TO THIS APPLICATION:

Objection List

- AS PER PREVIOUS COMMENT: "VALUES SHOWN ON PW3 FORM ARE INCORRECT IN QUANTITY AND/OR ACCURATELY REPRESENT A REASONABLE VALUATION OF SPRINKLER SYSTEM PER AC \$28-112.3." AS PER OB TOOLS THE COST IS \$XXXXXXX. PLEASE RECTIFY THE COST AND RE-SUBMIT PW3 FORM.
EME Response: The scope of work does not include a sprinkler system. Therefore the PW3 does not include a valuation of the sprinkler system. The PW3 for this project has been re-uploaded.
- AC 28-104.7 PROVIDE LETTER THAT THE BUILDING IS CITY-OWNED PROPERTY. PROVIDE A LETTER WITH LETTER HEAD INSTEAD OF AI1 FORM.
EME Response: A letter indicating that the building is city owned property has been uploaded.
- AC 28-104.7 PROVIDE THE USAGE OF EXISTING ROOM BEFORE CONVERSION.
EME Response: The usage of the existing rooms prior to conversion is stated in the occupancy notes located on page A-002.00.
- AC 28-104.7 PROVIDE ANY CONJUNCTION OR ANY JOB TYPE RELATED TO THIS APPLICATION FA JN#.
EME Response: No new fire alarm devices are being installed so FDNY filing is not required. Only scope of work is relocation of existing device.
- AC 28-104.7 - PLEASE PROVIDE THE FOLLOWING, "THE EXISTING CONDITION IS CAPABLE TO SUPPORT THE SCOPE OF WORK". TEMP SHORING REQUIRED??
EME Response: Note added on page A-100.00, "All walls shall be left in stable condition at the end of each shift, unless condition is safe enough to be self supporting."
- AC 208-104.7 VERIFY IF ANY PL FIXTURE BE MODIFY OR ALTER AS PART OF THE SCOPE OF WORK?
EME Response: The plumbing fixtures will not be modified or altered as part of the scope of work. The area of work is located in the changing room adjacent to the toilet room.
- 247 SF
EME Response: The square footage has been noted on the occupancy notes located on page A-002.00.

Applicant's Statement:

I have self-certified compliance of objections. I am aware that the commissioner will rely on the truth and accuracy of the above statement as to compliance with the provisions of all applicable building laws and regulations. If non-compliance with such laws is disclosed at any later examination or review, I will take the necessary remedial measures to obtain objection compliance expeditiously.

I further understand the falsification of facts will render me liable for any legal and disciplinary action by the Department of Buildings and other appropriate authorities.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print) Michael McNamara Date 02/28/2020
Signature _____
P.E. / R.A. Seal (apply seal, then sign and date over seal)

