




AI1: Additional Information Must be typewritten.



Page number _____ of _____ BIS Document No. 01

1 Location and Job Information Required for all applications.

House No(s) 200-16 Street Name 44 Avenue
Borough Queens Block 5523 Lot 13 BIN 4214616 CB No. 411

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☒ Yes PW1 required ☐ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page. Is this section continued on additional AI1 forms? ☐ Yes ☒ No

3 Additional Information Required for all applications.

Objection: AOS1 missing sign and seal and owners signature, resubmit
Response: fully-executed AOS1 resubmitted to file via upload

Objection: Remove inapplicable inspections, coordinate with TR1 and inspections listed on sheet T001.00
Response: T001.00 and TR1 Design are correct as submitted. Special Inspections: Fire Resistant Penetrations and Joints; Progress Inspections: Final Inspection Dir. 14/75; Energy Code: Interior Lighting Power, Lighting Controls


Objection: 1968 Code Occupant Load Requirements Table 6-2 Provide Occupant load calculations
Response: Occupant Load computations, per Table 6-2, (16 ppl.) added to Occupancy Section, drawing LS-100.00

Objection: PC 403 Provide plumbing fixture calculations
Response: Added Table re Min. Plumbing Fixtures computation on drawing LS-100.00 (see top right of the drawing)

Objection: Substantiate existing zoning use group and existing occupancy
Response: refer to CO # 213943 issued 3-11-91 for Block 5523, Lot 13; Use Group 6, Offices (E occupancy)

Objection: BC 1103.1 Provide dimension, demonstrate compliance with accessible route.
Response: Refer to Life Safety Plan LS-100.00

Objection: Provide detail drawings indicating (including but not limited to) clear floor space, fixture clearances, dimensions per BC 1109 and ANSI
Response: Refer to drawing G-001.00 for fixture mounting heights and clearances for ADA compliance; Added enlarged detail on drawing A-700.00



Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print) Theodore Radovici
Signature [Signature] Date 05/18/20
P.E. / R.A. Seal (apply seal, then sign and date over seal)