

PARKER AND WEST ENGINEERING, PLLC

1425 PARKER ST. BRONX NY 10462

Phone: (917) 251-0319

email: INFO@PARKERWESTENG.COM

Website: PARKERWESTENG.COM

May 19, 2020

Sunrun Inc.

133 Technology Dr. Suite 100

Irvine, CA, 92618

Re: Structural Certification for Installation of Solar Panels

Sunrun Job Tracking Number: 216R-003AMIR

Plans: Rev A Dated May 19, 2020

Client: MYROON AMIROOLA

Address: 125-03 115TH AVE, QUEENS, NY, 11420

To Whom It May Concern:

A structural evaluation of the loading was conducted for the above address based on the design criteria listed below.

Design Criteria:


- 2017 NYSBC including 2015 IBC/IRC/IEBC and ASCE 7-10
- Ground Snow Load = 25 psf
- Basic Wind Speed = 118 mph, Exposure Category C.

Based on this evaluation, I certify that the alteration to the existing structure by installation of the PV system meets the requirements of the applicable existing building provisions adopted/referenced above.

Additionally, I certify that the PV module assembly has been reviewed to be in accordance with the manufacturer's specifications and has been determined to meet and/or exceed all the requirements set forth by the referenced codes for loading.

Installer shall inspect the existing roof framing to verify it is in suitable condition and does not exhibit any signs of damage which may diminish the capacity of its members or connections prior to commencement of PV installation.

Sincerely,



Walid Abdulla, P.E.

Manager

Parker and West Engineering, PLLC

