



AI1: Additional Information Must be typewritten.

☒ Orient and affix BIS job number label here ☒

Page number 1 of 1

BIS Document No. 01

440637330

1 Location and Job Information Required for all applications.

House No(s) **115-46**

Street Name **126TH STREET**

Borough **QUEENS**

Block **11669**

Lot **28**

BIN **4252223**

CB No. **410**

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes PW1 required ☒ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page.

Is this section continued on additional AI1 forms? ☐ Yes ☒ No

3 Additional Information Required for all applications.

RESPONSE TO OBJECTIONS DATED 11/04/2020:

1. Objection #1: Provide survey. Verify existing bulk.

RESP.: Survey has been uploaded. Approved Plan set for Job #: 401642040 has been provided to verify existing.

2. Objection #2: Provide prior approved plan 40142040. Prove existing conditions.

RESP.: Approved plan for job # 401642040 has been uploaded, showing existing conditions.

3. Objection #3: New roof area >200 sqft. Show method of storm water disposal with drywell, grit chamber details, drywell calculation, required soil percolation tests and connection piping on the site plan as per LL103/89. Show that drywell is adequately sized as per RS 16 and P110.13. Drywells shall be located 5ft from all lot lines and 10ft from foundations.

RESP.: Drywell is not required as extension on first floor is 28.50 sf. Over hang of second floor extension is 71.20 sf, totaling to 99.70 sf. Therefore drywell is not required as proposed extension cover's 99.70 sf.

4. Objection #4: Required Items: ZD1, ST1. Sustainable roof zone form.

RESP.: Required items have been uploaded.

5. Objection #5: See Marked-up Plan.

RESP.: Drawings have been updated to reflect comments on marked-up Plans.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print) **HANSA PERSAUD** **11/11/2020**
Signature _____ Date _____

P.E. / R.A. Seal (apply seal, then sign and date over seal)

