



STORM

BOROUGH OF Staten Island

CERTIFICATE OF INSPECTION - NEW SEWER HOUSE CONNECTION

This below described sewer house connection has been laid from the property line to the existing sewer at premises:

(N.B.#) P.R.A. 510003782 Block 201 Lot 70

Under Permit Number 559640 Issued 12-09-09

Premises 120 Bodine Street

Located West side 25.34 feet North of De Groot Pl.

Owner Michael Jordan

Plumber Thomas Sardanelli

Size and type of pipe laid 6" XHCI

Connected to 24" STORM Sewer laid in

Bodine Street

I hereby certify that I made the inspection of the Sewer House Connection described above and that all work done under this permit has been properly completed in accordance with existing ordinances, rule and regulations.

Name Leonid Maksimovskiy

Signed [Signature] Date: 12-16-09

Noted [Signature] Date: 12-24-09

PENALTY FOR FALSIFICATION:

Falsification of any statement made herein is an offense punishable by a fine, imprisonment or both (N.Y.C. Administrative Code, Section 1151-90)

Copies to: Borough SP, Department of Buildings
 Borough Office, Bureau of Water Registrar
 Sewer Regulation and Control Section

File original in Borough Office, Sewer Regulation & Control HC 02A (REV 6/03)



124	Bodine street	201	71
house number	street name	block	lot

1. Was connection extended from curb connection? ☐ yes, ☒ no
2. Was the connection placed on earth stone or crushed rock, concrete cradle, concrete encasement or reinforced concrete encasement? (circle one)
3. Was connection made to existing spur or riser or new riser, fold in supr, MH connection or cut in? (circle one)
4. If connection was "cut in", was saddle or dutchman used? (If so, circle)
5. Length, size and material of new connection 28' of 6" X HCT, 25' of 4" X HCT
6. Depth of connection at curbline is 7' feet
7. All work was exposed and inspected.

