

DIFFENDALE & KUBEC, A.I.A.

350 PORT RICHMOND AVENUE, Suite 201 STATEN ISLAND, NY 10302 Tel (718) 447-3714 Fax (718) 447-3715

ARCHITECTS / PLANNERS

October 28, 2009

NYC Department of Buildings
Borough Hall
Staten Island, New York 10301



RE: Application 510028916

918 Rathbun Avenue, Staten Island
Tax Block: 6924 Lot: 63

**SUBJECT: REQUIRED CONTROLLED INSPECTIONS OF CONCRETE FOR
RESIDENTIAL DWELLINGS**

To whom it may concern:

Under the 1968 Building Code the 2,000psi Concrete used in this dwelling is not subject to "Site Controlled Inspection" [Form TR 1], however the concrete poured is required to have a Semi-Controlled Inspection [Concrete Lab Cylinder Test Report] for verification as to the actual concrete strength.

Form TR3 is for the special design of concrete 3000psi or stronger. As this dwelling required only 2000psi concrete the TR3 form is not required.

Very truly yours,

DIFFENDALE & KUBEC, A.I.A.


Wallace Kubec, R.A.

