

ORDER TYPE POMTR PO-METER PERMIT

PAGE 1 OF 2

ACCOUNT 3001038824001

NAME SCOTT LIEBERMAN

PHONE 917-509-4888

ADD NM

BORO 5 BLK 7499 LOT 22

SEC 30 COMM BRD 503

ADDR 19 STALIE CT

SPCL PREM INS

STATEN ISLAND NY 10309

SPCL READ INSTR

BUILDING CLASS

A9 MISCELLANEOUS

CROSS STREETS

NOT AVAILABLE

NOT AVAILABLE

UMS VARIANCE CODE

NON UMS VARIANCE CODE



ASGN TO 0000 STATUS A PEND/INITIATED REAS A NORMAL
 CONTRACT 0000 BATCH 00000 PLACED BY THOMAS SARDANELLI
 WANTED BY DATE 10/19/12 TIME 0000 CREATED BY MD
 CONTRACT ITEM CODES
 SPCL INST PO-METER PERMIT INSTALL 3/4" DISP METER N/B#520051648

ISS DATE 10/25/11
 PH #
 DATE 10/19/11

POMTR - PO-METER PERMIT

PERMIT NUMBER 612720

SVC SIZE 004 SVC SIZE DESC 1 - 1/2" TAP SIZE 004 TAP SIZE DESC 1"

FEE 35.00 NO DAYS USAGE 000 START/END DATE 00/00/00 00/00/00

APPLICATION DATE 00/00/00 EXPIRE DATE 00/00/00 START/END TIME 0000 0000

PLUMBER LICENSE NO 0001039 EXPIRE DATE 01/26/13 STATUS A ACTIVE-GOOD

NAME THOMAS SARDANELLI

ADDRESS 40 LASALLE ST STATEN ISLAND NY 10303

ADDITIONAL ORDER INFORMATION

METER PERMIT

NOTE: ALL METERS MUST BE REMOTE READY.

PERMIT ORDER STATUS

() G -- PERMIT COMPLETED

() P -- PERMIT CANCELED

NEW METER ATTRIBUTE AND NEW METER INSTALLATION INFORMATION FOR METER NUMBER:

() ☒ NEW METER MANUFACTURER *Neptune (Pro)*
 () ☒ NEW METER SIZE *3/4"*
 () ☒ NEW METER TYPE *T-10*
 () NEW METER LOCATION CODE
 () ☒ NEW METER SERIAL NUMBER *#52279417*
 () NEW METER READING 1
 () NEW METER READING 2 (FOR COMPOUND METER)
 () NEW REMOTE ID 1
 () NEW REMOTE ID 2 (FOR COMPOUND METER)
 () NEW REMOTE LOCATION CODE
 () LOW FLOW - IN-READ/ OUT READ
 () INTERFLOW - IN-READ/OUT READ
 () HIGH FLOW - IN-READ/OUT READ
 () CAPACITY (GALLONS, CUBIC FEET)
 () NUMBER OF READ DIALS-1
 () TOTAL NUMBER OF DIALS-1
 () NUMBER OF READ DIALS-2 (FOR COMPOUND METER)
 () TOTAL NUMBER OF DIALS-2 (FOR COMPOUND METER)
 () CONSTANT
 () MEASURES (CCF, GALLONS)
 () CAPABILITIES (PB-PRIMARY BYPASS OR MNL-MAINLINE)
 () SEAL NUMBER 1
 () SEAL NUMBER 2 (FOR COMPOUND METER)

METER TEST DATE

| --- | --- |

2011 OCT 25 PM 3:53

Jan. 18. 2012 12:32PM

ABLE ISLAND PLUMBING

No. 0267 P. 2

ORDER TYPE POMTR PO-METER PERMIT

ACCOUNT 3001038824001

NAME SCOTT LIEBERMAN

PAGE 2 OF 2

PHONE 917-509-4888

METER TESTED BY (INSPECTOR ID): -

I HERBY CERTIFY THAT ALL CONNECTIONS ARE PROPER AND THAT THE PREMISES ARE METERED IN ACCORDANCE WITH THIS PERMIT.

DATE SET:

PLUMBER NAME:

PLUMBER ADDRESS:

1/16/12
Thomas Sardannelli
Quality Plumbing
40 LaSalle St.
SE-N.Y. 10303

Thomas Sardannelli

IF CALIBRATION WAS REQUIRED, WAS THE METER CALIBRATED IN PLACE?

() YES

() NO

COMPLETION DATE

WO STATUS

COMPLETED BY (ID)

WO STATUS REASON

COMPLETION TIME IN

COMPLETION TIME OUT

COMMENTS

2011 OCT 25 PM 3:53

19 Shive Q.

52279417

NEPTUNE

HIGH 99.0

INT 101.1

LOW 100.4

11/03/11 7:58 AM

Pallet # 10

Position # 7

00111010080

00111011004