




AI1: Additional Information Must be typewritten.



Page number 1 of 1 BIS Document No. 3

1 Location and Job Information Required for all applications.

House No(s) 263 Street Name Father Capodanno Boulevard
Borough Staten Island Block 3122 Lot 158 BIN 5170558 CB No. 502

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes PW1 required ☒ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID
S	T-101.02	T-101.03	S	A-201.01	A-201.03						
S	Z-100.01	Z-100.03	S	A-202.01	A-202.03						
S	A-100.01	A-100.03	S	FO-100.01	FO-100.03						
S	A-200.01	A-200.03									

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page. Is this section continued on additional AI1 forms? ☐ Yes ☒ No

3 Additional Information Required for all applications.

RESPONSE TO OBJECTIONS RECEIVED 11/21/2018:

1. OBJECTION - PW1A Please update dwelling unit values where "Part of a Dwelling Unit" is listed.

RESPONSE- Dwelling units revised on PW1A.

2. OBJECTION - ZONING -The zoning diagram revisions and zoning table provided in the plan set and ZD-1 reflect different values (ex. Building height, perimeter height). Please clarify.

RESPONSE- Zoning diagram, table and ZD1 have been clarified and are aligned.

3. OBJECTION - PLAN SET - Please clarify the side yard dimension and which dimensions of the floor plan at the first and second floor have changed due to the increase in side yard. Please clarify if there are any changes to the floor area and room areas due to the increase in the side yard dimension.

- Please revise the DFE shown in the zoning diagrams, elevations, and sections as per BC Appendix G.

- Please clarify the material used for the panel behind the lift and if it meets the requirements for flood damage resistant materials as per BC G304.1.1.4.

- Please revise the flood vent calculations to reflect the vent added as per BC G104.5.1.1.

RESPONSE- floor area, room areas and window ratios updated revised due to change in side yard.

- DFE revised.

- Contractor shall remove panel behind lift

- flood vent calculations revised on FO-100 sheet.

RESPECTFULLY REQUEST REVIEW OF PLAN SET CHANGES FOR CLOSE OUT:

T-101.03 - REVISED SHEET LIST

Z-100.03 - REVISED SIDE YARD AND FINAL ELEVATIONS PER AS BUILT CONDITIONS, REVISED ZONING DIAGRAMS, AND TABLES TO BE ALIGNED, REVISED DFE.

A-100.03 - REMOVED STAIR PIERS AND COLUMNS, REVISED SIDE YARD, ADDED WOOD SCREEN BEHIND ADA LIFT, REVISED GAS METER LOCATION AND ADDED FLOOD VENT

A-200.03 - REMOVED STAIR PIERS AND COLUMNS, REVISED SIDE YARD, ADDED WOOD SCREEN BEHIND ADA LIFT, REVISED GAS METER LOCATION AND ADDED FLOOD VENT; REVISED ADA LIFT LOCATION, REVISED FLOOR AREA AND WINDOW CALCS DUE TO INCREASE IN SIDE YARD.

A-201.03 - REVISED ELEVATIONS, STAIR COLUMNS AND PIERS, GAS METER LOCATION AND FLOOD VENT. REVISED DFE

A-202.03 - REVISED ELEVATIONS IN SECTION VIEW.

FO-100.03 - REMOVED STAIR PIERS AND COLUMNS, ADDED WOOD SCREEN BEHIND ADA LIFT, REVISED GAS METER LOCATION AND ADDED FLOOD VENT, REVISED FLOOD VENT CALCULATIONS

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print) Melanie Cragnolin, PE 1/22/2019

Signature Melanie Cragnolin Date

P.E. / R.A. Seal (apply seal, then sign and date below seal)

