



FIRE DEPARTMENT
9 METROTECH CENTER BROOKLYN, N.Y.



Date: 07/10/18

NYC Department of Buildings
Plumbing Section

Borough of: ☐ Bronx ☐ Brooklyn ☐ Queens ☐ Manhattan ☒ Staten Island

Re: Rest. Name: In Fire kettle
Premise Address: 401 Jewell Ave
Borough / Zip: Staten Island NY 10314
DOB / FP Appl. No.: 520330794
Fire Department Plan No.: 38104154
DOB Cooking Equipment Job #: N/A

Dear Sir / Madam:

On June 10, 2018 a Fire Department representative witnessed a performance test of the Apex R102-36.1x2 UL300 system at the subject premise. The test was satisfactory.

NOTE: ** Gas shut-off valve subject to the approval by the Department of Buildings.

** Occupancy: ☒ Under 75 Persons ☐ Over 75 Persons

BY ORDER OF CHIEF OF FIRE PREVENTION

Ronald Spadoni

Prepared by:

Michael Peersaud FBI

Name and Title

Copy to: Dancy FD Tag No.: 10851

Copy to: FD 01 F.I.C William Hind Co Inc