


OFFICE COPY



DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER & SEWER OPERATIONS
HOUSE CONNECTION PROPOSAL FORM
For 1, 2, or 3, Family Homes Only

VALID FOR TWO (2) YEARS

IHC - / /



PROJECT DATA:

Borough of STATEN ISLAND Building Dept. No (s) TO BE SELF CERTIFIED
Tax Block 6677 Lot (s) 27, 28, 29, 34 Zoning R3X Map No. 33B
Project Location 78, 82, 86, 90, 94 HOLLEN AVENUE, 168, 172 MACGREGOR STREET
Applicant RICHARD W. DAILEY, P.E. - ROGERS CALVANICO GROUP
Address 2420 ARTHUR KILL ROAD, STATEN ISLAND, NY Zip 10309 Phone (718) 447-6801
Owner KNOX STREET BUILDERS, ROBERT KELLY - MEMBER
Address 900 SOUTH AVENUE SUITE 204, STATEN ISLAND, NY Zip 10314 Phone (718) 987-3000

1. PLAN:

See Attachment 'F'

DEP
Inspection

2. HOUSE CONNECTIONS REQUESTED:

Total developed Site Storm Flow 2.47 cfs
Allow. Storm Flow to the Sewers 0.37 cfs

☐ Detention ☐ Retention

No. Requested	Sanitary	Storm	Comb.	Drywells
Size	7	1	xxxxxxx	xxxxxxxxx
Material (s)	6"	6"	xxxxxxx	xxxxxxxxx
Total Q (s)	E.H.C.L.	E.H.C.L.	xxxxxxx	xxxxxxxxx
	0.030	0.36 CFS	xxxxxxx	2.11 CFS

Note: The property owner is responsible for plugging all inactive pre-existing sewer connections.

3. CONNECTION INFO:

1. ☐ Connection to exist: 1 SANITARY
☐ Spur ☐ Riser ☒ Curb Connection

2. ☐ Proposed New Riser

3. ☐ Fold Spur in

4. ☒ Drill in 6 SANITARY; 1 STORM

5. ☐ M.H. Conn. ☐ Exist. ☐ Prop.

6. ☐ Reuse Plugged Connections

SEWER INFORMATION CERTIFIED BY DEP

PUBLIC PRIVATE

1. There (is) (is not) a sanitary sewer fronting the property available for connections.

SIZE

10

2. There (is) (is not) a storm sewer fronting the property available for connections.

SIZE

24

3. There (is) (is not) a combined sewer fronting the property available for connections.

SIZE

only for lot # 42

4. Sanitary discharge tributary to:

City Treatment Plant -
Private Sewage Treatment Plant -
Private Pumping Station -

☒ YES
☐ NO

☒ YES
☐ NO

0.13

Location

5. Distance to, and location of nearest allowable drainage plan sewer:

a) Sanitary Outlet
b) Storm Outlet
c) Combined Outlet

N/A

none within 200'

CERTIFICATION, RESTRICTIONS, SPECIAL CONDITIONS:

NO CONNECTION PERMIT WILL BE
ISSUED UNTIL TENTATIVE LOT SHEET IS
FINALIZED

By MWR Date APR 16 2021
CITY OF NEW YORK
DEPT. OF ENVIRONMENTAL PROTECTION
Bureau of Water & Sewer Permitting Section
APPROVED
Rev. 5/05

N.T.S.

MATERIAL NOTE:

THE PIPE AND BEDDING MATERIAL FOR THE PROPOSED CONNECTIONS SHALL CONFORM TO STANDARD N.Y.C.D.E.P. SPECIFICATIONS.

NOTE:

THE FLOW RATE TO THE DRYWELLS IS PER DEP REQUIREMENTS AND THAT THE DRYWELLS ARE IN COMPLIANCE WITH DOB RULES.

BLOCK 6677

