



March 19, 2014

Judith Hoot
1st Light Energy
1869 Moffat Blvd.
Manteca, CA 95336

Re: 104 Ryan Place
Staten Island, NY 10309
MC - 46594

Dear Judith Hoot,

Please be advised that the interconnection application, including the **Contractor Certification and the three-line diagram accepted by Consolidated Edison**, for the Photovoltaic Distributed Generation Installation at the above – referenced address has been reviewed and is accepted for inter-connection to and operation in parallel with the Consolidated Edison system as of 3/4/14.

You are advised that this authorization is limited to a determination that the installation described above is accepted by Consolidated Edison and does not mean that the design and installation of your DG equipment is in compliance with any other requirements, including local building codes and ordinances. **You are reminded that your contract for the Interconnection of a New Distributed Generation Unit with a Capacity of 2 MW or Less requires the Customer to obtain all environmental and other permits required by governmental authorities for the construction and operation of the Unit.**

Finally, you are reminded of the requirement to contact Consolidated Edison to obtain approval before any modifications is made to your equipment. You are further reminded of the continuing obligation to perform verification testing at least once every four years as well as any verification tests prescribed by the manufacturer and to maintain a log of these tests for inspection by Consolidated Edison.

Sincerely,
Brian Fitzgerald
Brian Fitzgerald
Staten Island Major Services

Attach
Cc: file