




AI1: Additional Information Must be typewritten.



Page number 1 of 1 BIS Document No. _____

1 Location and Job Information Required for all applications.

House No(s) 282 Street Name Brighton Street
Borough Staten Island Block 788 Lot 29 BIN 5087971 CB No. 503

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes PW1 required ☒ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page. Is this section continued on additional AI1 forms? ☐ Yes ☐ No

3 Additional Information Required for all applications.

This additional Information form is being filed to address all comments issued to application #540070206 certifying that all comments have been addressed.

1. 1 RCNY 105-02 - Provide lot diagram - At a minimum include the following: North arrow Streets – distance to street Dimension of lot Block/Lot Adjacent buildings (if attached/semi-detached) Building height/stories Panel locations Trees, utility poles – or other falling hazards.

Answer: Drawing S-001.00 updated.

2. AC 28-104.7.1 - Provide note on cover sheet: Scope of work is solely for the installation of the Solar Electronic Generating System. All other work is not to be relied upon as being approved and/or permitted by the Buildings Department.

Answer: Note provided

3. Provide elevations to confirm that building / panels fit within required NYC Zoning Resolution height/setback envelope.

Answer: Elevations provided.

4. Note that Solar Panels are not a permitted obstruction within a required front, side or rear yard per ZR 23-44.

Answer: SOLar panels will be located on the roof only.

5. Demonstrate compliance with FC 512.3.1, FC 512.4.1 and FC 512.4.2.

Answer: Drawings updated.

6. AC 28-104.7.1 - Clarify roof configuration

Answer: Drawing updated, clarification provided.

7. Confirm compliance with FC 504.4.7

Answer: Note provided.

8. TR1 Form - Coordinate

Answer: Special inspections listed on drawing S007.00.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print) Louis P. Ramunno
Signature _____ Date _____
P.E. / R.A. Seal (apply seal, then sign and date over seal)

