



Environmental
Protection

Emily Lloyd
Commissioner

James J. Roberts
Deputy Commissioner
Bureau of Water &
Sewer Operations

59-17 Junction Blvd.
Flushing, NY 11373

DEPT OF BLDGS540115579 Job Number

ES152497121 Scan Code

9/17/2015

Attn:

To Whom It May Concern:

The hydrant flow test you requested at **Wavecrest Street** between **Cedar Grove Avenue** and **Dead End, Staten Island** was performed on **9/16/2015 at 2:34 PM** with the following results:

The static pressure taken on an 8 inch water main which is fed from one direction on the north side of Wavecrest Street 2nd hydrant west of Cedar Grove Avenue was 66 pounds per square inch. The residual pressure at this point was 58 pounds per square inch when 500 gallons of water per minute were flowing from the north side of Wavecrest Street 3rd hydrant west of Cedar Grove Avenue.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

If you have any questions regarding engineering, and application status, please call (718) 595-3958.

Very truly yours,

Jose A. Cortes, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2015-5502-514108

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$500 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.