



Buildings



LAA Permit Department of Buildings

Permit Number: 100831272-LAA

Issued: 07/08/1994

Expires: 07/08/1995

Address: MANHATTAN 215 WEST 88 STREET

Issued to: JERRY DIFALCO

Business: ROYAL FLUSH PLBG AND HTG

Floors: 11E

Licensee No: P - 001223

Description of Work: *Plumbing: OTHER PLUMBING*

TO TEST EXISTING GAS PIPING TO STOVE FOR CON ED., DUE TO SMALL FIRE INSIDE THE APT. THE PIPING SIZE IS 3/4" AND THE EXISTING STOVE IS 30,000 BTU'S.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/16/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.