



Buildings



LAA Permit Department of Buildings

Permit Number: 101704728-LAA

Issued: 09/10/1997

Expires: 09/10/1998

Address: MANHATTAN 65 NAGLE AVENUE

Issued to: ADAM ABRAMOWITZ

Floors: ALL

Business: WARD PLG

Licensee No: P - 001443

Description of Work: Plumbing: OTHER PLUMBING

CON EDISON TURNED OFF GAS DUE TO LEAK ON OVERHEAD GAS MAIN. REPAIR LEAK AND PERFORM INTEGRITY TEST ON ALL OVERHEAD RISERS (5) AND BRANCHES. TOTAL 20 APTS IN THE BUILDING. - TO INSTALL 26 NEW GAS METERS PROVIDED BY CON ED. INTEGRITY TEST TO BE PERFORMED ON ALL OVERHEAD RISERS (5) AND BRANCHES.

Emergency Telephone Day or Night: 311

Borough Commissioner:

A stylized, handwritten signature of the Borough Commissioner, appearing as a series of loops and a long horizontal stroke.

Commissioner of Buildings:

A handwritten signature of the Commissioner of Buildings, which reads "James S. Oddo" in a cursive script.

This permit copy created on 11/25/2025 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.