



Buildings



LAA Permit Department of Buildings

Permit Number: 102273923-LAA

Issued: 03/21/2003
7:38 PM

Expires: 03/21/2004

Address: MANHATTAN 368 EIGHTH AVENUE

Issued to: ANTHONY NASTASI

Business: NASTASI PLBG & HTG INC

Floors: BAS,001

Licensee No: P - 000942

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Gas Usage(s): Heat

TO TEST THE GAS MAIN LINE, GOING TO THE HOT AIR IN THE FIRST FLOOR STORE. TO CHANGE ALL THE SECTIONS THAT FAIL. TO CHANGE THE REAR SECTION OF THE MAIN, WH-ERE IT IS UNDERSIZED(REPLACE APPROX. 80 FEET OF 1/2" WITH 1" AND 3/4" PIPING,AS NEEDED.) TO HANG AND SECURE THE ENTER GAS LINE. TO FILE THE JOB VIA ARA. NO

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 08/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.