



**Buildings**

# LAA Permit Department of Buildings

Permit Number: **103874167-LAA**

Address: **MANHATTAN 40 DOWNING STREET**

**Floors: CEL**

Description of Work: **oil: OIL TANK**

**REPLACE BOILER & OIL BURNER (NYC BOILER MD23660-01) & CONNECT TO EXISTINGMASONRY CHIMNEY AT CELLAR. EMERGENCY INSTALLATION PER PPN 7/99. ALT II & 2NDFEE BE PE WITHIN 60 DAYS. ACTUAL BTU'S--INPUT:1,106,000 OUPUT:901,000EXP DATE: 01/16/09.**

**Issued: 01/16/2008  
10:53 AM**

**Expires: 01/16/2009**

**Issued to: DOMINICK J RUTIGLIANO**

**Business: ROCKWAY FUEL OIL CORP**

**Licensee No: O - 002718**

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/21/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.