



Buildings



LAA Permit Department of Buildings

Permit Number: 110242899-LAA

Issued: 10/10/2008
11:48 AM

Expires: 10/10/2009

Address: MANHATTAN 360 EAST 55 STREET

Issued to: JOHN SORRENTINO

Floors: 001 thru 015

Business: A.D.S. PLBG & HTG, INC

Licensee No: P - 001321

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Gas Usage(s): Cooking

CODE 1968 REPLACE BRANCH LINES FROM M-RISER TO METER IN APT#2M,5M,6M,7M,8M,9M,10M FOR EXISTING COOKING STOVES. REPLACE APPROX. 63 FT OF 3/4" GAS PIPING. ALSO REPLACE GAS COCKS & GAS FLEXIBLE BEHIND THE STOVE IN APTS#1M THRU 15M. GAS CARD NEEDED. REMOVE DRIP TEE FROM RISER IN CELLAR. EXP 10/10/08

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 12/29/2025 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.