



Buildings



LAA Permit Department of Buildings

Permit Number: 110497230-LAA

Issued: 01/21/2010
3:05 PM

Expires: 01/21/2011

Address: MANHATTAN 48 EAST 43 STREET

Issued to: SEBBY CRAPANZANO

Floors: BAS

Business: GENERAL PLUMBING CORP

Licensee No: F - 000939

Description of Work: Fire Suppression: ADD/REPLACE/REPAIR/REARRANGE SPRINKLER HEADS/PIPING

FURNISH & INSTALL ONE 1-NEW 3/4" AUTOMATIC BALL DRIP BETWEEN THE LOWER CHECKVALVE & THE SPRINKLER SIAMESE CONNECTION-AS PER 901.6 OF FIRE CODE.TO COMPLY WITH NYC FD VIOL#11161167X.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/31/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.