



Buildings



LAA Permit Department of Buildings

Permit Number: 110510670-LAA

Issued: 05/25/2010
2:25 PM

Expires: 05/25/2011

Address: MANHATTAN 1049 PARK AVENUE

Issued to: PHILIP J KRAUS

Floors: 008

Business: FRED SMITH P&H CO INC

Licensee No: P - 000620

Description of Work: *Plumbing: GAS EQUIPMENT/PIPING*

Gas Usage(s): Cooking

REPAIR LEAK ON 3/4" GAS BRANCH THAT FEEDS THE EX'G STOVE IN APT 8C. 3/4" NIPPLE AT THE INLET TO THE APPLIANCE'S GAS COCK WAS TIGHTENED & NO NEW PIPING WAS USED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/16/2024 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.