



Buildings

LAA Permit Department of Buildings

Permit Number: 110520749-LAA

Issued: 11/18/2010
11:09 AM

Expires: 11/18/2011

Address: MANHATTAN 59 EAST 79 STREET

Issued to: CARMINE SPRIO

Floors: CEL

Business: CITY/SUBURBAN PLBG CORP

Description of Work: Plumbing: PRIMARY BACKFLOW PREVENTER (RPZ)

Licensee No: P - 000950

1 1/2" DOM RPZ-BFP WILKINS 975 XL, MEA#425-89M, 2-1/2" DOUBLE CK. DETECTOR WILKINS 350 DA, MEA#147-99-M INSTALLED IN THE CELLAR. PIPING SIZE FOR DOMESTIC SERVICE 1 1/2" FROM SERVICE ENTRY TO METER 3'-6", METER TO BFP 10'-0", BFP TO TEST TEE 10"-0", TEST TEE TO MOCV 0"-6". PIPING SIZE FOR FIRE SVC ENTRY TO DSDA4

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/25/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.