



Buildings



LAA Permit Department of Buildings

Permit Number: **110534306-LAA**

Issued: **03/29/2011**
10:55 AM

Expires: **03/29/2012**

Address: **MANHATTAN 1465 AMSTERDAM AVENUE**

Issued to: **RONALD C PESCATORE**

Floors: **CEL 001 thru 005**

Business: **ADVANTAGE PLBG & MECH.COR**

Licensee No: **P - 001286**

Description of Work: **Plumbing: GAS EQUIPMENT/PIPING**

Gas Usage(s): Cooking

RUN ABOUT 30'X1 1/4" BLACK PIPE FROM METER IN CELLAR-2FL & TIE INTO EXISTING REMAINING RISER FOR B LINE. C LINE IS HOLDING WILL TEST 4 APTS ON LINE. RUN 60'X1 1/4" BLACK PIPE TO REPLACE A LINE & TEST. WORK ON CEL, 1-5FL APTS 1A, 2A, 2B, 2C, 3A, 3B, 3C, 4A, 4B, 4C, 5A, 5B, 5C, 5D. ALL TESTED. FIRE STOP DISTURBED & REPLACED.

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/22/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.