



**Buildings**

# **LAA Permit Department of Buildings**

Permit Number: **110555462-LAA**

Issued: **10/20/2011  
8:31 AM**

Expires: **10/20/2012**

Address: **MANHATTAN 30 WEST 13 STREET**

Issued to: **DAVID J CATANEO**

Floors: **CEL**

Business: **GATEWAY PLUMBING & HTNG**

Description of Work: **Plumbing: PRIMARY BACKFLOW PREVENTER (RPZ)**

Licensee No: **P - 001468**

**INSTALL ONE 6" WILKINS DOUBLE CHECK DETECTOR MODEL 350ADA, MEA#221-04-M VOL 2( FOR SPRINKLER) AND ONE 2" WILKINS DOUBLE CHECK BACKFLOW PREVENTER MODEL 950XLT , MEA#426-89-M (FOR DOMESTIC) ON EXISTING COMBINATION 6" DOMESTIC/SPRINKLER SERVICE. DEP APPROVAL#11031784.**

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/22/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.