



## LAA Permit Department of Buildings

Permit Number: 110565068-LAA

Address: MANHATTAN 61 JANE STREET

Floors: CEL

Issued: 01/11/2012 11:58 AM Expires: 01/11/2013 Issued to: RICHARD A BELLINI Business: VARSITY PLBG & HTG INC Licensee No: P - 001356

Description of Work: Plumbing: PRIMARY BACKFLOW PREVENTER (RPZ)

INSTALL 1 RPZ ON EXISTING COMBINED WATER SERVICE AND 1 DCDA ON EXISTING FIRE S ERVICE. ONE 4" CONBRACO 40-200 RP40, MEA#451-04-M RPZ & ONE 6" CONBRACO 4SG-60 0, MEA#195-08-M DCDA. DEP APPROVAL#11035901. 0103LS

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

James S. Oddo

This permit copy created on 11/24/2024 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.