



Buildings



LAA Permit Department of Buildings

Permit Number: 110579990-LAA

Issued: 10/08/2012
10:39 AM

Expires: 10/08/2013

Address: MANHATTAN 400 WEST 119 STREET

Issued to: PETER AGLIARDO JR

Floors: BAS

Business: PETER AGLIARDO CONTRACTOR

Licensee No: O - 002626

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CONVERT EXISTING OIL BURNER FROM #6 TO #4 OIL. BOILER:2 FEDERAL FST-100, MEA#1 73-77E. BURNER: 2 ICI DEG-42P, MEA# 86-70EIII, INSTALLED UNDER APPLICATION#MISC 1488/86. NYC BOILER MD 7374-01-02 CONNECTED TO EXISTING MASONRY CHIMNEY AT BAS T. 16800000BTU. PRIMARY OIL PREHEATER TO BE REMOVED. DEP# CA2426/86M. ANTISHYPHON DEVICE TO BE INSTALLED AT HIGH POINT IN OIL SUPPLY LINE BETWEEN OIL TANK AND OIL BURNER.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 08/17/2025 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.