



Buildings

LAA Permit Department of Buildings

Permit Number: 110581816-LAA

Issued: 10/04/2012
10:57 AM

Expires: 10/04/2013

Address: MANHATTAN 241 WEST 97 STREET

Issued to: MICHAEL A MANISCOLCO

Floors: CEL

Business: APPROVED OIL CO OF BKLYN

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

Licensee No: O - 002709

WE WILL CHANGE THE FUEL GRADE FROM #6 TO #4. WE WILL REMOVE THE PRE-HEATERS AND INSTALL AND ANTI-SYPHON VALVES FOR THE EXISTING EQUIPMENT. 2 EXISTING BOILER S BOTH FEDERAL FST 400 16,800,000BTUS MEA 173-77E AND BURNERS BOTH INDUSTRIAL COMBUSTION DEG-175P TO REMAIN. THERE IS NO CHANGE IN THE FIRING RATE. THE DEP INSTALLATION NUMBER IS CA000488J. 0919RA

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/20/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.