



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 110583707-LAA

Issued: 01/29/2013  
12:15 PM

Expires: 01/29/2014

Address: MANHATTAN 140 ORCHARD STREET

Issued to: ANTONIO A DUMITRIU

Floors: CEL 001 thru 005

Business: APOLLO PLBG & HTG INC

Licensee No: P - 002252

Description of Work: *Plumbing: GAS EQUIPMENT/PIPING*

*Gas Usage(s): Cooking*

*DUE TO GAS LEAK CONED SHUT OFF GAS FOR ALL 15 APTS.(1,2,3,4,5,6,7,8,9,10,11,12,13,14,15).  
INSTALLING 15 NEW CLASS 250 METER BARS FOR EACH APT. AND 15 3/4 BRANCH LINES FOR EACH  
APT. RUNNING APPROX 750' OF 1 1/2" GAS PIPE FROM 1ST TO 5TH FLR. EACH FLOOR HAS 3 APTS.  
EACH APT HAS ITS OWN METER. NO FIRESTOPS BEING COMPROMISED GAS FOR COOK. GAS TEST  
REQUIRED.*

1026LF/0104LF/0122LF

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 11/16/2024 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.