



Buildings

LAA Permit Department of Buildings

Permit Number: **110586768-LAA**

Issued: **12/31/2012
11:10 AM**

Expires: **12/31/2013**

Address: **MANHATTAN 327 CENTRAL PARK WEST**

Issued to: **JEFFREY SOLOMON**

Floors: **CEL**

Business: **ABILENE, INC**

Licensee No: **O - 002693**

Description of Work: **oil: OIL WORK - FUEL GRADE CHANGE**

FUEL GRADE WILL CHANGE FROM FROM #6 OIL TO #2 OIL.

WE WILL REMOVE A PRE-HEATER. WE WILL INSTALL \AN ANTI-SIPHON VALVE.

THERE IS NO CHANGE OF FIRING RATE.

NO ACP5 REQUIRED.

DEP INSTALLATION #CB139306K.

12/19LAA EMERG MAIL.

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings: **Acting Commissioner of Buildings**

This permit copy created on 01/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.