



Buildings



LAA Permit Department of Buildings

Permit Number: 121647147-LAA

Issued: 08/19/2013
5:00 PM

Expires: 08/19/2014

Address: MANHATTAN 96 MORTON STREET

Issued to: IRWIN H BRENNER

Floors: ROF

Business: GENERAL PLUMBING CORP

Licensee No: F - 000785

Description of Work: Fire Suppression: REPLACE/REPAIR SP/SD

REPLACE DEFECTIVE SPRINKLER UPPER CHECK VALVE WITH A NEW 8" UL/FM APPROVED CHECK VALVE.
SPRINKLER SYSTEM TO BE SHUT OFF FOR APPROX. SIX (6) HOURS. REFER TO EWN #8934.

0722MAIL/0809MAIL

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 04/11/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.