



Buildings



LAA Permit Department of Buildings

Permit Number: 121647664-LAA

Issued: 08/22/2013
9:32 AM

Expires: 08/22/2014

Address: MANHATTAN 317 WEST 87 STREET

Issued to: DAVID E BARR

Floors: CEL

Business: CHIEF ENERGY CORP

Licensee No: 0 - 004261

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CHANGE GRADE OF FUEL FROM #6 TO #4. A PRE-HEATER WILL BE REMOVED AND AN ANTI-SYPHON VALVE WILL BE INSTALLED. NO CHANGE IN FIRING RATE. DEP INSTALLATION #CA057980Z.

0801GS/0813AJ

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/24/2024 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.