



Buildings

LAA Permit Department of Buildings

Permit Number: 121650828-LAA

Issued: 10/28/2013
11:44 AM

Expires: 10/28/2014

Address: MANHATTAN 2581 BROADWAY

Issued to: JOSEPH PIETRACATELLA

Floors: BAS

Business: PRESTIGE PLBG & HTG INC

Description of Work: Plumbing: PRIMARY BACKFLOW PREVENTER (RPZ)

Licensee No: P - 001904

INSTALL (1) 1 1/2" WILKINS 975XL RPZ, MEA # 425-89-M VOL. 3 ON EXISTING DOMESTIC WATER SERVICE. INSTALL (1) 3" WILKINS 350ADA DOUBLE DETECTOR CHECK, MEA #221-04-M-2 ON EXISTING SPRINKLER SERVICE. INSTALL APPROX. 6' OF 1 1/2" COPPER PIPE FROM EXISTING WATER METER TO NEW RPZ. INSTALL APPROX 6' OF 1" COPPER PIPE FOR RPZ DISCHARGE TO NEW 3" FLOOR DRAIN. DEP APPROVAL #13046772.

0923KP/PP

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/20/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.